WIGGIN AND DANA

Counsellors at Law

Wiggin and Dana LLP One Century Tower P.O. Box 1832 New Haven, Connecticut 06508-1832 www.wiggin.com Bruce L. McDermott 203.498.4340 203.782.2889 fax bmcdermott@wiggin.com

September 23, 2010

Honorable Daniel Caruso Chairman Connecticut Siting Council 10 Franklin Square New Britain, CT 06051

Re:

Docket F-2010

Dear Chairman Caruso,

During last week's F-2010 hearing, the panel from The United Illuminating Company ("UI") was asked about the yearly impact of Distributed Generation ("DG") on energy and system peak. Following the hearing, UI undertook to confirm the response given during the hearing and in so doing discovered that the impact to system energy requirements and the impact to system peak was not based on the same forecast of customer-side DG projects. A more current customer-side project DG list was used for forecasting the impact to system energy requirements.

As a result, the forecasted normal weather scenario and extreme weather scenario system peak has been updated to reflect the customer-side DG project list used to forecast system energy requirements. The update includes modifications to both the normal weather scenario and extreme weather scenario system peak and associated calculations - annual change and 2009 - 2019 growth - as presented in Exhibit 1 of UI's report. The update also includes modifications to Table 2 of the response to Interrogatory CSC-4. The revisions do not result in modifications to the system energy requirements, weather adjusted sales as presented in Exhibit 1 or the peak load scenario for ISO-NE regional transmission planning process presented in Exhibit 2 of UI's report since DG is treated as a resource rather than a reduction in load.

WIGGIN AND DANA

Counsellors at Law

Daniel Caruso September 23, 2010 Page 2

Please do not hesitate to call me should you have any questions concerning this filing.

Very truly yours,

DALL. WICDCIII

Enclosures

cc: Service List

10705\1228\2423842.1